

✓ JLC
3/11/17
CAC
2/27/17

DEPARTMENT OF INSPECTIONS AND APPEALS

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: S0107	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 01/12/2017
--	--	--	--

NAME OF PROVIDER OR SUPPLIER
LAKEVIEW LODGE

STREET ADDRESS, CITY, STATE, ZIP CODE
**312 SOUTHBROOKE DR
WATERLOO, IA 50702**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	<p>481-67 Initial Comments</p> <p>Assisted Living Programs are defined by the type of population served. The census numbers were provided by the Program at the time of the on-site.</p> <p>Dementia-Specific Program by Definition Number of tenants without cognitive disorder: 11 Number of tenants with cognitive disorder: 38 Total population of Program at time of on-site: 49 Total census of Assisted Living Program: 49</p> <p>The following regulatory insufficiencies were cited during the investigation of Incident # 65071-I:</p>	A 000	<p>See attached</p> <p>POC 3/14/17</p>	
A 013	<p>481-67.3(2) Tenant Rights</p> <p>481-67.3 Tenant rights. All tenants have the following rights: 67.3(2) To receive care, treatment and services which are adequate and appropriate.</p> <p>This REQUIREMENT is not met as evidenced by: Based on interviews and record review, staff failed to provide adequate and appropriate care for 1 of 1 tenants reviewed who eloped from the Program (Tenant #1). Findings include:</p> <p>Tenant #1 was admitted to the Program on 1/5/17 with a diagnosis of short-term memory impairment, anxiety with depression, hypertension, chronic headaches, hyperlipidemia, esophageal reflux, vitamin B-12 anemia, and Schatzki's ring S/P dilation. Tenant #1 scored a 28 on the Mini-Mental State Exam on 1/5/17.</p>	A 013		

DIVISION OF HEALTH FACILITIES - STATE OF IOWA
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

DEPARTMENT OF INSPECTIONS AND APPEALS

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: S0107	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 01/12/2017
--	--	--	---

NAME OF PROVIDER OR SUPPLIER LAKEVIEW LODGE	STREET ADDRESS, CITY, STATE, ZIP CODE 312 SOUTHBROOKE DR WATERLOO, IA 50702
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 013	<p>Continued From page 1</p> <p>An incident report dated 1/8/17 at 11:00 AM, revealed Tenant #1 eloped from the building. At approximately 11:15 AM, a hospital representative called the facility and reported Tenant #1 was at the hospital and a police officer would be bringing him/her back to the Program. Tenant #1 was returned and assessed for injury. No injuries were noted and a Wander Guard was put in place.</p> <p>A review of the nursing communication book revealed the following notes regarding Tenant #1:</p> <p>a. 1/5/17: Tenant #1 was admitted to the facility today. His/her niece is staying the night. He/she is forgetful and has anxiety issues - may be a problem when niece leaves. Try the cheerful/happy approach - invite to activities and introduce to others.</p> <p>b. 1/6/17: Tenant #1 may need some extra tender loving care and extra cheerful approaches when niece leaves - he/she has a history of anxiety.</p> <p>On 1/12/17 at 9:30 AM, review of the security video footage for 1/8/17 revealed Tenant #1 left the building out the front door as a visitor was holding open the door to carry out boxes at 10:20 AM. The video showed Tenant #1 quickly walked out with no coat on. Shortly after the tenant exited, Staff B went out the door and after Tenant #1. Staff D went to the entryway and observed. The video footage then showed on 1/8/17 at 10:55 AM, Tenant #1 went out the front door a second time and down the street. No one else was observed in the video. Tenant #1 appeared to wear a coat, scarf, shoes, and pants. Additional layers of clothing were visible beneath his/her coat. It could not be determined how the Tenant was able to leave the front door without the alarm sounding or if the alarm had sounded</p>	A 013		

DEPARTMENT OF INSPECTIONS AND APPEALS

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: S0107	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B WING _____	(X3) DATE SURVEY COMPLETED C 01/12/2017
--	--	--	---

NAME OF PROVIDER OR SUPPLIER LAKEVIEW LODGE	STREET ADDRESS, CITY, STATE, ZIP CODE 312 SOUTHBROOKE DR WATERLOO, IA 50702
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

A 013	<p>Continued From page 2</p> <p>and was turned off by someone.</p> <p>According to wunderground.com, on 1/8/17 at 10:54 a.m., the temperature was 10 degrees Fahrenheit (F) with a wind chill of -3.7 degrees F.</p> <p>Record review revealed the Registered Nurse (RN) documented in interdisciplinary notes, dated 1/8/17 at 3:15 p.m., at 11:30 a call was received from the front office informing them Tenant #1 was found by a good Samaritan. The good Samaritan took Tenant #1 to the local emergency room. Tenant #1 reported to the good Samaritan he/she was running away. The RN contacted the emergency room to confirm the tenant was there and was informed he/she was and would be returned to the Program by police. A head to toe assessment was completed upon the tenant's arrival.</p> <p>When interviewed on 1/11/17 at 3:45 p.m., Tenant #1 reported he/she was upset about moving. He/she reported he/she ran away because he/she "just had it."</p> <p>On 1/11/17 at 1:10 PM, Staff D stated she was one of two staff working on the floor where Tenant #1 resided on the day of the elopement. Staff D stated that on the day prior to the elopement (1/7/17) Tenant #1 had been anxious and stated he/she didn't like it there and was going to leave. The tenant's niece had stayed over night but left on the morning of 1/8/17. Staff D stated Resident #1 was anxious all morning prior to the elopement. At one point, Tenant #1 told Staff D it was very cold in his/her room. Staff D found an open window in the tenant's apartment and shut it. Staff D took her break in the break room at 10:45 AM that morning, leaving Staff B to cover the floor. At 11:00 AM, Staff D got off break and</p>	A 013		
-------	--	-------	--	--

DEPARTMENT OF INSPECTIONS AND APPEALS

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: S0107	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED C 01/12/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER LAKEVIEW LODGE	STREET ADDRESS, CITY, STATE, ZIP CODE 312 SOUTHBROOKE DR WATERLOO, IA 50702
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 013	<p>Continued From page 3</p> <p>went to give Tenant #1 his/her meds. Tenant #1 could not be located in the building. At approximately 11:15 AM, the emergency room contacted the facility and reported Tenant #1 was at the hospital and would be brought back to the facility by police. Staff D reported when Tenant #1 returned, he/she wore a coat and shoes. Staff D stated she did not hear any door alarms sound during that time frame.</p> <p>On 1/11/17 at 4:30 PM, Staff B confirmed she was one of two staff working on the floor where Tenant #1 resided on the day of the elopement. Staff B stated she met Tenant #1 that day. She described Tenant #1 as being anxious that morning. Prior to the elopement at 10:55 AM, Tenant #1 had walked out the front door at the same time a visitor was leaving. Staff B stated she followed the tenant out and walked with her back in the building. She found out Tenant #1 was missing at around 11 AM when Staff D asked if she had seen Tenant #1. Staff B had been at the end of the East hall in another tenant's room helping with cares at that time. Staff B did not heard any alarms sound during the time the tenant eloped.</p> <p>A review of nursing delegations revealed staff were trained on the facility's procedures for restless or wandering tenants. Staff B was trained on 10/28/16 and Staff D was trained on 10/5/16. Neither staff member implemented strategies from this training after the first attempted elopement. Staff B went to the end of the East hallway and into a tenant's room. Staff D went on break. This left Tenant #1 alone with no staff supervision just minutes after being brought back in from attempting to leave the building.</p>	A 013		

DEPARTMENT OF INSPECTIONS AND APPEALS

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: S0107	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 01/12/2017
--	--	--	---

NAME OF PROVIDER OR SUPPLIER LAKEVIEW LODGE	STREET ADDRESS, CITY, STATE, ZIP CODE 312 SOUTHBROOKE DR WATERLOO, IA 50702
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 138	Continued From page 4	A 138		
A 138	<p>481-69.32(2) Life Safety</p> <p>481-69.32(231C) Life safety-emergency policies and procedures and structural safety requirements.</p> <p>69.32(2) An operating alarm system shall be connected to each exit door in a dementia-specific program.</p> <p>This REQUIREMENT is not met as evidenced by: Based on observations and staff interview the facility failed to ensure all alarms on doors were operating correctly and were loud enough for staff to hear. Findings include:</p> <p>On 1/11/17 at 1:45 PM during an observation of a door alarm demonstration by the Maintenance Supervisor, the door alarm shut off as soon as the 15 second delayed egress time frame was over and the door opened. At 4:50 PM, the Maintenance Supervisor stated the alarms were to continue to sound after the door opened until shut off by a person by putting in the code on the keypad.</p> <p>On 1/11/17 at 1:52 PM, the surveyor stood in the staff break room with the door ajar and had the Maintenance Supervisor activate the front, main door alarm. The surveyor could not hear the alarm sounding from the break room area.</p> <p>On 1/11/17 at 5 PM, Staff E tested all of the alarmed doors for the surveyor. Out of 9 doors tested, 4 doors had alarms that shut off automatically after the door opened. This demonstration revealed the door alarms were not all working properly. Upon closer examination of the front door alarm, it was discovered if</p>	A 138		

DEPARTMENT OF INSPECTIONS AND APPEALS

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: S0107	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 01/12/2017
--	--	--	---

NAME OF PROVIDER OR SUPPLIER LAKEVIEW LODGE	STREET ADDRESS, CITY, STATE, ZIP CODE 312 SOUTHBROOKE DR WATERLOO, IA 50702
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

A 138	<p>Continued From page 5</p> <p>someone used the code on the keypad to bypass the alarm system, there was actually a 37 second window when the door remained unalarmed. This time frame could potentially provide easy access out the door without setting off an alarm if a tenant followed behind someone using the keycode.</p> <p>On 1/11/17 at 1:30 PM, the Maintenance Supervisor stated he had maintenance/security staff check the alarms each night to ensure they worked properly. According to alarm check documentation, the alarms were checked consistently each night.</p> <p>On 1/12/17 at 10:25 AM, Staff F stated he often did the alarm checks during the night shift. Staff F stated he only checked two doors in the entire building each night, the front door and a side glass door. He said he never went to the 2nd floor and checked those exits or any other doors on the 1st floor.</p> <p>On 1/12/17 at 12:00 PM, the Director confirmed the door alarms were not working properly. At the time of the exit, the alarm system company was at the Program making repairs.</p>	A 138		
-------	---	-------	--	--



Friendship Village

MyLife Retirement Living

February 24, 2017

Catie Campbell, Program Coordinator

Adult Services Bureau

Health Facilities Division

Re: Lakeview Lodge Incident #65071-1

VAK
3/1/17
CAC
2/27/17

BOARD MEMBERS

Mr. Brad Morris
Past Chairman

Mr. Robert Smith, Jr.
Chairman

Mr. Craig Anderson
Vice Chairman

Mr. Ronald Kiewiet
Secretary

Mr. Jay Nardini
Treasurer

Mr. George Farber
Mr. Ronald Fiacco
Mr. James Grady
Ms. Terri Seegers
Pastor Chris Rygh
Mr. Robert Smith, Sr.
Mr. Mark Tink
Pastor Ron Weimer
Pastor Tom Hlad

EMERITUS

Mr. Walter Cochran
Mr. Dale Peterson
Mrs. Nancy Shirey

Marion Ahrenholz, 1928 - 1968
Edward M. Tink, 1926 - 1982
Kenneth J. Stultz, 1919 - 1998
Raymond L. DeBar, 1926 - 2009
Dr. Albert Nesbit, 1925 - 2011
Warren Wiele, 1934 - 2012
Pastor David Moore, 1929 - 2016

CHAPLAIN

Pastor Ron Weimer

PRESIDENT/CEO F.O.F

Lisa Gates

Lakeview Lodge Plan of Correction

A 013 - 481-67.3(2) Tenant Rights

1. Program will retrain current staff on interventions and procedures for restless and wandering tenants. Staff will sign off on receiving this training.
2. New employees will be trained in orientation on the above procedures. All staff will be trained annually within their required dementia hours.
3. Program director and nurse coordinator will periodically audit staff performance visually when interacting with restless and wandering residents, as well as audit staff files to ensure trainings have been completed.
4. Date insufficiency will be corrected - 3/14/17

A 138 - 481-69.32(2) Life Safety

1. All doors were mag-locked on 1/11/17 so they would not egress until they could be fixed. Contracted alarm system company was onsite 1/12/17 to correct all doors not operating to our standards, and continued to work on each one until all parts arrived and were finished.
2. New sounders were installed at the ends of hallways and back of building to ensure alarms could be heard from all areas when sounding.
3. Doors alarms are checked once a day to ensure they properly alarm and relock. Wander guard door alarms are checked once a day to ensure they properly alarm.
4. Date insufficiency was corrected - 2/6/17

Sincerely,

Emily Miller, Director

Lakeview Lodge

319-291-1350

emiller@fvrc.com